



**ADDENDUM NO. 03
September 04, 2018**

To Drawings and Specifications dated June 29, 2018.

**RIVER OAKS ELEMENTARY SCHOOL – Fire Alarm / Intrusion Alarm Upgrades
Galt Joint Union Elementary School District**

Prepared by: **PBK**
2520 Venture Oaks Way, Suite 440
Sacramento, California 95833

PBK Project Nos.: 17232

- A. Receipt of this Addendum shall be acknowledged on the Bid Form.
- B. This Addendum forms part of the Contract documents for the above referenced project and shall be incorporated integrally therewith.
- C. Each bidder shall make necessary adjustments and submit this proposal with full knowledge of all modifications, clarifications, and supplemental data included therein. Where provisions of the following supplemental data differ from those of the original Contract Documents, this Addendum shall govern.

GENERAL INFORMATION

Item No. 1 **Reference Fire Alarm System Component Schedule on Sheet E4.04, and specification section 266113: Revise Fire Alarm Control Panel to Silent Knight 6820EVS and the Fire Alarm Voice Remote Control Unit to Silent Knight EVS-LOC.**

END OF ADDENDUM NO. 03